


Construction Details

Series V Model VF1 Closed Circuit Cooling Towers Model VC1 Evaporative Condensers







MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT	HEAVIEST SECTION (COIL)	F	Н
VC1-30	2010	2300	2010 🛦	13 1/4"	6'-7 1/4"
VC1-38	2240	2560	2240 🛦	21 3/4"	7'-3 3/4"
VC1-46	2540	2880	1650	30 1/4"	8'-0 1/4"
VC1-52	2590	2930	1700	30 1/4"	8'-0 1/4"
VC1-58	2860	3230	1940	38 3/4"	8'-8 3/4"
VC1-65	2930	3300	2010	38 3/4"	8'-8 3/4"
				The state of the s	

NOTES:

- 1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
- 2. UNLESS OTHERWISE INDICATED, ALL CONNECTIONS 6 INCHES AND SMALLER ARE MPT AND CONNECTIONS 8 INCHES AND LARGER ARE BEVELED FOR WELDING.
- 3. DIMENSIONS SHOWING LOCATION OF COIL CONNECTIONS ARE APPROXIMATE AND SHOULD NOT BE USED FOR PREFABRICATION OF CONNECTING PIPING.
- 4. FOR SUPPORT REQUIREMENTS, REFER TO THE SUGGESTED STEEL SUPPORT DRAWING.

B.A.C. ORDER NO:	BALTIMORE AIRCOIL	RIGHT HAND UNIT SIDE OUTLET WITH PUMP FULL CIRCUIT	
DATE:	COMPANY	DRAWING NUMBER: BAC-9827 A	